SANDIA REPORT

SAND2017-4043 Unlimited Release April 2017

Proposal for Monitoring Within the Centrifuge Cascades of Uranium Enrichment Facilities

David R. Farrar

Prepared for "Weapons of Mass Destruction Non-Proliferation Science and Policy" Course University of New Mexico Spring 2017

Prepared by Sandia National Laboratories Albuquerque, New Mexico 87185 and Livermore, California 94550

Sandia National Laboratories is a multi-mission laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.

Approved for public release; further dissemination unlimited.



Issued by Sandia National Laboratories, operated for the United States Department of Energy by Sandia Corporation.

NOTICE: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government, nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees, make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represent that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government, any agency thereof, or any of their contractors or subcontractors. The views and opinions expressed herein do not necessarily state or reflect those of the United States Government, any agency thereof, or any of their contractors.

Printed in the United States of America. This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from

U.S. Department of Energy Office of Scientific and Technical Information P.O. Box 62 Oak Ridge, TN 37831

Telephone: (865) 576-8401 Facsimile: (865) 576-5728 E-Mail: reports@osti.gov

Online ordering: http://www.osti.gov/scitech

Available to the public from

U.S. Department of Commerce National Technical Information Service 5301 Shawnee Rd Alexandria, VA 22312

Telephone: (800) 553-6847 Facsimile: (703) 605-6900 E-Mail: orders@ntis.gov

Online order: http://www.ntis.gov/search



SAND2017-4043 Unlimited Release April 2017

Proposal for Monitoring Within the Centrifuge Cascades of Uranium Enrichment Facilities

David R. Farrar
Radiation Protection
Sandia National Laboratories
P.O. Box 5800
Albuquerque, New Mexico 87185-MS0651


CONTENTS

1. Introduction	7
2. Additional Benefits of Monitoring System Within Cascade	8
3. Arguments Against Monitoring System Within Cascade	8
4. Conclusion	10
5. References	10
Distribution	11
FIGURES	
Figure 1 - Example of monitoring a uranium enrichment system with enrichment monitors	
(CEMOs and AEMs) (Ianakiev et al, 2008).	7
Figure 2 - Diagram of gas centrifuge (Ulmer-Scholle, 2016).	
Figure 3 - Bank of centrifuges at a uranium enrichment facility (World Nuclear Association,	
2016)	9

1. Introduction

Safeguards are technical measures implemented by the International Atomic Energy Agency (IAEA) to independently verify that nuclear material is not diverted from peaceful purposes to weapons (IAEA, 2017a). Safeguards implemented at uranium enrichment facilities (facilities hereafter) include enrichment monitors (IAEA, 2011). Figure 1 shows a diagram of how a facility could be monitored.

Figure 1 - Example of monitoring a uranium enrichment system with enrichment monitors (CEMOs and AEMs) (lanakiev et al, 2008).



However, enrichment monitors are based on the high purity germanium detector (Ianakiev et al, 2008), which is expensive technology, and require relatively high pressure of uranium hexafluoride (UF $_6$) in the flow (Ianakiev et al, 2008). The interior of a centrifuge enrichment system consists of a large number of centrifuges (World Nuclear Association, 2016), in which the pressure of UF $_6$ in the flow is relatively low (Ianakiev et al, 2008). Therefore, enrichment monitors are not applicable for the interior.

The use of a system for monitoring within centrifuge cascades is proposed. The monitoring system would be designed to detect diversion of centrifuges away from a facility's monitored enrichment system. After design, the system would need to be built and tested in order to assess its capability. If its capability is sufficient for detecting diversion of centrifuges, then it would need to be customized for feasible use by the IAEA as a part of their safeguards. This customization may need to be facility-specific.

2. Additional Benefits of Monitoring System Within Cascade

A monitoring system within centrifuge cascades could provide benefits to the IAEA in addition to detecting secondary enrichment capability that is separate from a monitored enrichment system. The monitoring system could find diversion of small amounts of uranium occurring from within the monitored enrichment system. Nuclear material accountancy by the IAEA is based on counting containers of material, weighing them, and measuring their emitted radiation (IAEA, 2011). Due to IAEA's limited resources, it may perform accountancy only at locations where accumulation of material is the largest. It is plausible that small amounts of material may be missing from these locations without the IAEA's knowledge. If the diversion of material occurs within the centrifuge cascade, a monitoring system within the cascade could catch it.

Also, a monitoring system within centrifuge cascades could determine the amount of centrifuges within a facility. This amount can be checked against the facility's declared amount of centrifuges. If there is a mismatch, this could indicate unauthorized export of nuclear technology, or enrichment beyond what was declared to the IAEA.

3. Arguments Against Monitoring System Within Cascade

One argument against a monitoring system within centrifuge cascades is the IAEA performs site inspections of facilities on a routine basis (IAEA, 2017b), and these inspections would catch any diversion of centrifuges. A centrifuge consists of one input and a few outputs pipes (shown in Figure 2), centrifuges are placed close together in a facility (example shown in Figure 3), a centrifuge cascade consists of a large number of centrifuges, and many parallel centrifuge cascades make up a facility (World Nuclear Association, 2016). These result in large amounts of pipes that inspectors would have to examine visually in order to find diversion of centrifuges. The limits on inspectors' time during an inspection prevent detailed examination of this magnitude.





Figure 2 - Diagram of gas centrifuge (Ulmer-Scholle, 2016).

Figure 3 - Bank of centrifuges at a uranium enrichment facility (World Nuclear Association, 2016).



Another argument is that any monitoring system within centrifuge cascades would be too expensive for the IAEA to use. This is because any system would need to monitor multiple (possibly a lot) points within the centrifuge cascades of a facility. Not only would the system require purchasing lots of monitors, the costs associated with deploying, maintaining, and extracting data from the monitors would be prohibitive as well. The IAEA uses monitors based on radiation detection technology (IAEA, 2011). There is a wide range of radiation detection technology available. Some technologies do not require power sources or computers when measuring radiation, can be left unattended, are easy-to-use, are commercially available in bulk, have relatively easy processes for extracting data on radiation measured, and are in extensive use in many different applications. Examples of radiation detection technology that meet these criteria are thermoluminescent and optically-stimulated luminescent dosimeters ([Knoll, 2010], [Thermo Fisher Scientific, 2016], [Landauer, 2016]).

The last argument addressed is facility owners would be reluctant to allow monitoring systems within their centrifuge cascades. Some of their concerns may include intrusiveness in the enrichment process, potential to obtain proprietary information with such a system, and alarms due to shutdown/disconnection of centrifuges for valid reasons (like maintenance and repair). The flows of UF₆ within/between centrifuges are relatively low and current intrusive monitors used by the IAEA are not used in these low flows (Ianakiev et all, 2008). So it is possible that any viable monitoring within centrifuge cascades would have to be non-intrusive. For the potential of obtaining proprietary information, monitoring systems can be made to be qualitative in nature (like the cascade enrichment monitor [IAEA, 2011]). A monitoring system for centrifuge cascades can have a similar function, which may alleviate concerns of obtaining proprietary data. Finally, alarms by a monitoring system may only trigger an investigation by the IAEA, and not directly lead to immediate conclusions of non-compliance. The investigations would give facility owners chances to explain their valid reasons for shutdown/disconnection of centrifuges.

4. Conclusion

Monitoring within centrifuge cascades of facilities is not currently performed by the IAEA as a part of international safeguards. A monitoring system would need to be designed, tested, and tailored such that the IAEA can use it in their safeguards of facilities. It is possible that monitoring within centrifuge cascades could also serve to verify declared amounts of centrifuges in a facility. Monitoring systems in centrifuge cascades have a higher probability of finding diversion of centrifuges than visual inspections by the IAEA. Some technology that could be used in monitoring systems is economical in terms of material and operations. Monitoring systems within centrifuge cascades can be designed in such a way to alleviate concerns from facility owners.

5. References

- IAEA. Safeguard Techniques and Equipment: 2011 Edition. International Nuclear Verification Series No. 1 (Rev. 2). International Atomic Energy Agency, Vienna, Austria. 2011.
- IAEA. Basics of IAEA Safeguards. Retrieved from https://www.iaea.org/topics/basics-of-iaea-safeguards on April 2, 2017.
- IAEA. IAEA Safeguards Overview. Retrieved from https://www.iaea.org/publications/factsheets/iaea-safeguards-overview on April 2, 2017.
- Ianakiev K. D., Alexandrov B. S., Boyer B. D., Hill T. R., MacArthur D. W., Marks T., Moss C. E., Sheppard G. A., and Swinhoe M. T. *New Generation Enrichment Monitoring Technology for Gas Centrifuge Enrichment Plants*. LA-UR-08-3949. Los Alamos National Laboratory. Los Alamos, NM (unlimited release). July 2008.
- Knoll, G. F. *Radiation Detection and Measurement*. Fourth Edition. John Wiley and Sons. Hoboken, NJ. 2010.
- Landauer. Luxel®+. Landauer. 2016.
- Thermo Fisher Scientific. *Thermo Scientific Harshaw TLD Materials and Dosimeters*. BR-RMSI-TLD-0616. Thermo Fisher Scientific. 2016.
- Ulmer-Scholle D. S. Uranium Enrichment. New Mexico Tech. Retrieved from https://geoinfo.nmt.edu/resources/uranium/enrichment.html. November 2016.
- World Nuclear Association. Uranium Enrichment. Retrieved from http://www.world-nuclear.org/information-library/nuclear-fuel-cycle/conversion-enrichment-and-fabrication/uranium-enrichment.aspx. November 2016.

DISTRIBUTION

1 University of New Mexico, Department of Political Science

Attn: Faraj Ghanbari

MSC 05-3070

1 University of New Mexico Albuquerque, NM 87131-0001

(electronic copy)

1	MS0899	Technical Library	9536 (electronic copy)
1	MS1371	Amir H. Mohagheghi	6833 (electronic copy)
1	MS1373	Mary Clare Stoddard	6831 (electronic copy)

